Campus UAB - Ronda de La Font del Carme, s/n E - 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.appluslaboratories.com



SIMPLIFIED TEST CERTIFICATE

Nr. 22/32303634 S

Bellaterra, November 02, 2022

SOLAR INNOVA GREEN TECHNOLOGY, S.L.

N.I.F.: B 54627278 Paseo de Los Molinos, 12 03660 - NOVELDA (Alicante) UNE-EN 14449:2006. Glass in building. Laminated glass and laminated safety glass

TEMPERED LAMINATED SAFETY GLASS
6+6mm (13 mm total)
MODULE SOLAR PHOTOVOLTAIC

TEST REQUESTED AND SUMMARY OF RESULTS:

Pendulum test, UNE-EN 12600:2003 and UNE-EN 12600:2003 ERRATUM:2011

Test performed on: from 22/09/2022 to 23/09/2022

CLASSIFICATION: 1 (B) 1

Note: the impacted side, following the petitioner's indications, was the darkest (active part of the cells).

Responsible for Construction Mat. **LGAI Technological Center S.A.**

Technical Manager **LGAI Technological Center S.A.**

Full results contained in the report / s original test to the client with file number 22/32303634

The results indicated refer exclusively to the sample, product or material delivered to the laboratory and tested under the conditions indicated in the standards or procedures cited in this document. Reproduction of this document is authorized only if done in its entirety. Reports signed electronically in digital format is considered an original document, as well as electronic copies. Printing paper has no legal validity.





Applus + guarantees that this work was carried out within the requirements of our Quality System and Sustainability, having complied with the contractual terms and legal regulations.

As part of our improvement program, thank you send us any comments you see fit, please contact the person responsible for signing that letter, or the Director of Quality Applus +, in the direction: satisfaccion.cliente@applus.com