

# SIMPLIFIED TEST CERTIFICATE

Nr 22/32308630 S


Bellaterra, December 15, 2022

**SOLAR INNOVA GREEN  
TECHNOLOGY, S.L.**

N.I.F.: B 54627278

Paseo de Los Molinos, 12  
03660 - NOVELDA (Alicante)

## SOLAR PHOTOVOLTAIC PAVING 600 x 600 x 19 mm



### Requested test and summary of results:

**UNE 41902:2017 EX(\*). Surfaces for pedestrian transit. Determination of the slip resistance by pendulum friction method. Dry test. Alternative method according to the Support Document DA-SUA/3 to the Basic Document DB-SUA.**

TEST DATE: November 28, 2022.

**PTV value of the sample: 64(\*)**

*According to the Support Document DA-SUA/3 to the Basic Document DB-SUA, Safety of use and accessibility of the Technical Building Code, as an alternative solution it is accepted that the risk of slipping in dry areas is adequately limited if the soil tested in According to the UNE 41902:2017 EX standard, it has a PTV value greater than 40 for surfaces with a slope of less than 6% and greater than 65 for surfaces with a slope equal to or greater than 6% and stairs.*

*The risk considered in dry interior areas is that of dry landslides, considering that when a floor accessible by the public and located in a dry interior area is occasionally wet, for example during cleaning, it is adequately marked.*

Responsible for Construction Mat.  
**LGAI TECHNOLOGICAL CENTER, S.A.**

Technician Responsible  
**LGAI TECHNOLOGICAL CENTER, S.A.**

The full results are contained in the certificate original test available to the client with number 22/32308630

The results shown refer exclusively to the sample, product or material submitted in the laboratory and tested under the conditions specified in the rules or procedures mentioned in this document. Only legally valid reports with original signatures or copies certified. (\*) The UNE 41902:2017 EX standard is canceled on 10/11/2022 and is replaced by the UNE-EN 16165:2022 standard, however the Technical Building Code continues to refer to the UNE 41902:2017 EX standard so it is the one that continues to be used for the test.

Applus+, ensures that this work has been done within the requirements of our Quality System and Sustainability, having fulfilled the contractual and legal regulations.

As part of our improvement program, please let us pass on any comments they consider appropriate, contact the person responsible for signing that letter, or the Director of Quality of Applus +, at: [satisfaccion.cliente@applus.com](mailto:satisfaccion.cliente@applus.com)